



EVPÜ[®]

NOTIFIED BODY No. 1293

CERTIFICATE OF CONSTANCY OF PERFORMANCE

No. 1293 – CPR – 0648 Rev.1

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

**Conventional fire alarm outdoor sounder
SF300, SF3000, SF400**

For specifications see Annex to this certificate

placed on the market under the name or trade mark of

Teletek Electronics JSC

2, Iliyansko Shose Str., NPZ Voenna Rampa, 1220 Sofia, Bulgaria

and produced in the manufacturing plant

Teletek Electronics JSC

2, Iliyansko Shose Str., NPZ Voenna Rampa, 1220 Sofia, Bulgaria

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

EN 54-3: 2001, EN 54-3:2001/A1:2002, EN 54-3:2001/A2:2006

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on November 6th, 2023 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



Nová Dubnica, November 6th, 2023

Michal Mišiak

054831

Annex to Certificate No. 1293 - CPR – 0648 Rev.1 from November 6th, 2023

General Information:

SF300, SF3000, SF400 are conventional fire alarm outdoor sounders.

Technical specifications:

Sounder type	Type B
Operating voltage	20-30VDC
Power consumption in alarm state	28mA @ 24VDC
Sounder frequency	3.1 ± 3.8kHz
Sounder level volume	95dB @ 1m
Operating temperature	-40°C to +85°C
Relative humidity resistance	(93±3)% @ +40°C
IP Protection degree	IP44
Weight	1.03kg
Dimensions	310x230x60mm

Essential characteristics	Harmonised technical specifications	Performance
	EN 54-3:2001 EN 54-3:2001/A1:2002 EN 54-3:2001/A2:2006	
Performance under fire conditions	cl. 4.2, 4.3, 5.2, 5.3, C.3.1=N/A, C.3.2=N/A, C.5.1 to C.5.3=N/A	Pass
Operational reliability	cl. 4.4, 4.5, 4.6, 5.4, C.4=N/A	Pass
Durability of operational reliability: temperature resistance	cl. 5.5, 5.6, 5.7, 5.8, 5.9	Pass
Durability of operational reliability: humidity resistance	cl. 5.8, 5.9, 5.10	Pass
Durability of operational reliability: shock and vibration resistance	cl. 5.12 to 5.15	Pass
Durability of operational reliability: corrosion resistance	cl. 5.11	Pass
Durability of operational reliability: electrical stability	cl. 5.16	Pass
Durability of operational reliability: resistance to ingress	cl. 5.17	Pass

History of certification

No.	Certificate No.	Description	Date of issue
1	1293-CPR-0648	Original certificate issued	May 9 th , 2019
2	1293-CPR-0648 Rev.1	New location of the company	November 6 th , 2023



Nová Dubnica, November 6th, 2023

Michal Mišiak