



EVPÜ[®]

NOTIFIED BODY No. 1293

CERTIFICATE OF CONSTANCY OF PERFORMANCE

No. 1293 – CPR – 0463

In compliance with the Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

**Intelligent analogue addressable fire alarm sounder
SensoIRIS WSOU-xx, MAGPRO-WS, Belinda WSOU-xx,
Erida WSOU-xx, Marl WSOU-xx, Smoke sense WSOU-xx**

For specifications see Annex

produced by

**Teletek Electronics JSC
14A Srebarňa Str., 1407 Sofia, Bulgaria**

and produced in the manufacturing plant

**Teletek Electronics JSC
14A Srebarňa Str., 1407 Sofia, Bulgaria**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard

EN 54-3: 2001/A2: 2006

under system 1 are applied and that

the products fulfil all the prescribed requirements set out above.

This certificate was first issued on February 2, 2015 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.


Nová Dubnica, February 2, 2015



Marking may only be used if conformity with all relevant and effective Directives of EP and Council is attested.

049796

EVPÜ a.s., Trenčianska 19, SK 018 51 Nová Dubnica, Slovak Republic, www.evpu.sk
Page 1/2 FCO 425-13



Marek Hudák
Director NB

Annex to Certificate No. 1293 - CPR - 0463 from February 2, 2015

General Information:

SensoIRIS WSOU-xx, MAGPRO-WS, Belinda WSOU-xx, Erida WSOU-xx, Marl WSOU-xx, Smoke sense WSOU-xx is an addressable wall mount sounders designed for installing in addressable fire alarm system supporting TTE communication protocol. The device is powered on from the panel and can be controlled via the communication protocol. The device SensoIRIS WSOU-xx, MAGPRO-WS, Belinda WSOU-xx, Erida WSOU-xx, Marl WSOU-xx, Smoke sense WSOU-xx is compatible with fire base B124.

Technical specifications:

Operation voltage	15-32V DC (Nom. 27V DC)
Nominal consumption (stand-by)	<500µA @ 27V DC
Number of tone types	32
Relative humidity resistance	(93 ± 3)% @ +40° C
xx - Color (according the model):	
- R	red
- WT	white transparent
- AT	amber transparent
- RT	red transparent

Any particular conditions applicable to the use of the products and other technical specifications are shown in the manual SensoIRIS WSOU-xx No.18020193, MAGPRO-WS No.18020180, Belinda WSOU-xx, Erida WSOU-xx, Marl WSOU-xx, Smoke sense WSOU-xx No.18020236.

Products parameters:

Essential characteristics	Performance	Harmonised technical specification
		EN 54-3:2001+A1:2002+A2:2006
Performance under fire conditions	Pass	cl. 4.2, 4.3, 5.2, 5.3
Operational reliability	Pass	cl. 4.4, 4.5, 4.6, 5.4
Durability of operational reliability and response delay; temperature resistance	Pass	cl. 5.5, 5.6, 5.7, 5.8, 5.9
Durability of operational reliability; humidity resistance	Pass	cl. 5.8, 5.9, 5.10
Durability of operational reliability; shock and vibration resistance	Pass	cl. 5.12 to 5.15
Durability of operational reliability; corrosion resistance	Pass	cl. 5.11
Durability of operational reliability; corrosion resistance	Pass	cl. 5.16
Durability of operational reliability; resistance to ingress	Pass	cl. 5.17

Nová Dubnica, February 2, 2015




 Marek Hudák
 Director NB