



DECLARATION OF CONFORMITY

We, Teletek Electronics JSC
Address: 2, Iliyansko shose Str.
NPZ Voenna Rampa
1220 Sofia, Bulgaria

Declares that the

Product: MAG8 Plus
MAG4Plus
Fire Line MAG8 Plus
Fire Line MAG4 Plus
AE/C5-8-16

Description: Conventional Fire Alarm Control Panel

Complies to the following standards:

EN 54-2:1997, EN 54-2:1997/AC :1999
EN 54-2:1997/A1: 2006
EN 54-4:1997, EN 54-4:1997/AC :1999
EN 54-4:1997/A1 :2002, EN 54-4:1997/A2: 2006
EN 60950-1:2006/A1:2010 + A2:2013 + A11:2009 + A12:2011
EN 55032:2015
EN 61000-3-2:2006/A1:2009 + A2:2009
EN 61000-3-3:2008

The following Regulation:

CPR № 305/2011
REACH No 1907/2006

And the following Directives:

2014/30/EU- EMC
2011/65/EU – RoHSII
2014/35/EU – LVD

Additional information:

First date of production: 02.2006

Certificate:

№ 1293 – CPR–0546 Rev.1 of November 6th, 2023 from Notified body № 1293 EVPU
№ 00132/101/1/2010 of May 31, 2010 from Notified body № 1293 EVPU

Test report:

№ 00258/2010/C of May 31, 2010 from Notified body № 1293 EVPU

2, Iliyansko shose Str.
NPZ Voenna Rampa
1220 Sofia, Bulgaria
11.12.2023

Yuliy Iliev
Quality Manager



1293