

DECLARATION OF CONFORMITY

We, Teletek Electronics JSC
Address: 2, Iliyansko shose Str.
NPZ Voenna Rampa
1220 Sofia, Bulgaria

Declares that the

Product: SIMPO
Description: Intelligent interactive analogue addressable fire alarm control panel

Complies to the following standards:

EN 54-2:1997; EN 54-2:1997/AC:1999; EN 54-2:1997/A1:2006
EN 54-4:1997; EN 54-4:1997/AC:1999; EN 54-4:1997/A1:2002
EN 54-4:1997/A2:2006
EN IEC 62368-1:2018
EN 55032:2015; EN 55032:2015/A11:2020 (Class A)
EN 50130-4:2011; EN 50130-4:2011/A1:2014
EN 61000-3-2:2006 + A1:2009 + A2:2009
EN 61000-3-3:2008

The following Regulation:

CPR № 305/2011
REACH № 1907/2006

And the following Directives:

2014/30/EU - EMC
2014/35/EU- LVD
2011/65/EU- RoHS II

Additional information:

First date of production: 09.2013

Certificate:

№1293-CPR-0401 Rev. 1 of November 6th, 2023 from Notified body № 1293 EVPU

Test report:

№ 00008/2014/C of March 25, 2014 from Notified body № 1293 EVPU

2, Iliyansko shose Str.
NPZ Voenna Rampa
1220 Sofia, Bulgaria
08.12.2023

Yuliy Iliyev
Quality Manager

