

## DECLARATION OF CONFORMITY

**We,** **Teletek Electronics JSC**  
**Address:** 2, Iliyansko shose Str.  
NPZ Voenna Rampa  
1220 Sofia, Bulgaria

**Declares that the**

**Product:** **SensoMAG MCP50 IP67**  
**Description:** Conventional fire alarm manual call point

**Complies with the following standards:**

**EN 54-11:2001**  
**EN 54-11:2001/A1:2005**  
**IEC 60529:1989 + A1:1999 + A2:2013**  
**EN 55032:2015**  
**EN 50130-4:2011 + A1:2014**

**The following Regulation:**

**CPR № 305/2011**  
**REACH No 1907/2006**

**And the following Directives:**

**2014/30/EC- EMC**  
**2011/65/EU – RoHSII**

**Additional information:**

**First date of production:** 12.2016

**Certificate:**

№1293–CPR-0539 Rev.1 of November 6<sup>th</sup>, 2023 from Notified body № 1293 EVPU  
№ 00006/101/1/2017 of February 08, 2017 from Notified body № 1293 EVPU

**Test report:**

№ 90002/2017 of January 31, 2017 from Notified body № 1293 EVPU

2, Iliyansko shose Str.  
NPZ Voenna Rampa  
1220 Sofia, Bulgaria  
11.12.2023

Yuliy Iliev  
Quality Manager



**1293**