



EVPÜ[®]

NOTIFIED BODY No. 1293

CERTIFICATE OF CONSTANCY OF PERFORMANCE

No. 1293 – CPR – 0703 Rev.1

In compliance with the *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

Intelligent analogue addressable electrical mains switching output module with built-in isolator SensolRIS MOUT-240, Belinda MOUT-240, Erida MOUT-240, Marl MOUT-240, Smoke sense MOUT-240, SensolRIS MOUT-240 IP55, SensolRIS MOUT-240 IP65, Expera Oi Mains IP55, Expera Oi Mains IP65, MAGPRO-R

For specifications see Annex to this certificate placed on the market under the name or trade mark of

Teletek Electronics JSC

2, Iliyansko Shose Str., NPZ Voenna Rampa, 1220 Sofia, Bulgaria

and produced in the manufacturing plant

Teletek Electronics JSC

2, Iliyansko Shose Str., NPZ Voenna Rampa, 1220 Sofia, Bulgaria

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard


EN 54-18:2005, EN 54-18:2005/AC:2007,

EN 54-17:2005, EN 54-17:2005/AC:2007

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on November 6th, 2023 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



Michal Mišiak

Nová Dubnica, November 6th, 2023

EVPÜ a.s., Trenčianska 19, SK 018 51 Nová Dubnica, Slovak Republic, www.evpu.sk

Page 1 / 2 FCO 425-13 Rev.1

054853

Annex to Certificate No. 1293 - CPR – 0703 Rev.1 from November 6th, 2023

Technical Specifications

SensoIRIS MOUT-240 (derived variants Belinda MOUT-240, Erida MOUT-240, Marl MOUT-240, Smoke sense MOUT-240, SensoIRIS MOUT-240 IP55, SensoIRIS MOUT-240 IP65, Expera Oi Mains IP55, Expera Oi Mains IP65, MAGPRO-R) is an electrical mains switching relay output control module designed for application in addressable fire alarm systems, supporting communication protocol.

SensoIRIS MOUT-240, Belinda MOUT-240, Erida MOUT-240, Marl MOUT-240, Smoke sense MOUT-240 is mounted in a separate small plastic box suitable for wall mounting, with transparent cover for visual inspection.

SensoIRIS MOUT-240 IP55, Expera Oi Mains IP55, MAGPRO-R are mounted in a separate plastic box suitable for wall mounting and IP55 protection.

SensoIRIS MOUT-240 IP65, Expera Oi Mains IP65 are mounted in a separate plastic box suitable for wall mounting and IP65 protection.

The device works with Operating voltage (16 – 32) VDC.

Essential characteristics	Harmonised technical specification		Performance
	EN 54-18:2005 EN 54-18:2005/ AC:2007	EN 54-17:2005 EN 54-17:2005/ AC:2007	
Response delay (response time)	cl. 5.2	---	Pass
Performance under fire conditions	cl. 5.1.4	cl. 5.2	Pass
Operational reliability	cl. 5.1.4	cl. 4	Pass
Durability of operational reliability: temperature resistance	cl. 5.3, 5.4	cl. 5.4, 5.5	Pass
Durability of operational reliability: vibration resistance	cl. 5.8 to 5.11	cl. 5.9 to 5.12	Pass
Durability of operational reliability: humidity resistance	cl. 5.5, 5.6	cl. 5.6, 5.7	Pass
Durability of operational reliability: corrosion resistance	cl. 5.7	cl. 5.8	Pass
Durability of operational reliability: electrical stability	cl. 5.2, 5.12	cl. 5.3, 5.13	Pass

History of certification

No.	Certificate No.	Description	Date of issue
1	1293-CPR-0703	Original certificate issued	October 28 th , 2020
2	1293-CPR-703 Rev.1	New location of the company and adding new variants with IP65 protection	November 6 th , 2023



Nová Dubnica, November 6th, 2023

Michal Mišiak