

BRE Global Ireland

Notified Body No. 2831
BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

Certificate of constancy of performance

2831-CPR-F1672

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

IRIS Intelligent Analogue Addressable Interactive Fire Alarm Control Panel

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade mark of:

Teletek Electronics JSC
14A Srebarna Street
Sofia 1407
Bulgaria

and produced in the manufacturing plant(s):

Teletek Electronics JSC
14A Srebarna Street
Sofia 1407
Bulgaria

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-2:1997 + A1:2006 – Control and Indicating Equipment
EN 54-4:1997 + A1:2002 + A2:2006 – Power Supply Equipment

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 16 October 2019 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



E. Mattie-Suleiman, Certification Engineer

Date of First Issue: 16 October 2019

Date of Issue: 16 October 2019

On behalf of BRE Global Assurance (Ireland) Limited

Issue number 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie

BRE Global Ireland

Notified Body No. 2831

BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland

T: +353 (0) 18824344

E: enquiries@breglobalireland.ie
www.breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F1672

IRIS Intelligent Analogue Addressable Interactive Fire Alarm Control Panel

IRIS (1-4)L M - Intelligent Analogue Addressable Interactive Fire Alarm Control Panel, metal housing
IRIS (1-4)L P - Intelligent Analogue Addressable Interactive Fire Alarm Control Panel, plastic housing

Incorporating the following modular units:

| | |
|-------------------------|--|
| uPC Board | Module IRIS uPC |
| LCD Board | Module IRIS LCD |
| LED Board | Module IRIS Light Panel includes boards uPC, LCD and LED |
| Outputs Board | Module IRIS Outputs |
| Relay Board | Module IRIS 4 Relay |
| PSU Board | IRIS Module Power supply |
| Redundant Network Board | Module Redundant Network IRIS/SIMPO |
| Loop TTE Board | IRIS Loop Expander TTE |


Certified with the following options with requirements from EN54-2:

- 7.8 Output to fire alarm devices (option with requirements)
- 7.9 Control of fire alarm routing equipment (options with requirements)
- 7.9.1 Output to fire alarm routing equipment (option with requirements)
- 7.10 Outputs to fire protection equipment (options with requirements)
- 7.10.1 Output type A (option with requirement)
- 7.11 Delays to outputs (option with requirements)
- 7.12 Dependencies on more than one alarm signal (option with requirements)
- 7.12.1 Type A dependency (option with requirement)
- 8.3 Fault signals from points (option with requirements)
- 9.5 Disablement of addressable point (option with requirements)
- 10 Test condition (option with requirements)

Notes:

1. The scope of the approval does not include the operation of the network functionality
2. The product approval does not constitute compliance with the fire detection and alarm system requirements of EN54-13.

IRIS (0) Repeater M - Intelligent Analogue Addressable Interactive Fire Alarm Control Panel - Repeater, metal housing


E. Mattie-Suleiman, Certification Engineer,
On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 16 October 2019

Date of issue: 16 October 2019

Issue number: 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie

BRE Global Ireland

Notified Body No. 2831

BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie


APPENDIX to Certificate of constancy of performance: 2831-CPR-F1672

IRIS (0) Repeater P - Intelligent Analogue Addressable Interactive Fire Alarm Control Panel- Repeater, plastic housing

Approved for use with the IRIS Intelligent Analogue Addressable Interactive Fire Alarm Control Panel

Incorporating the following modules:

| | |
|-------------------------|--|
| uPC Board | Module IRIS uPC |
| LCD Board | Module IRIS LCD |
| LED Board | Module IRIS Light Panel includes boards uPC, LCD and LED |
| PSU Board | IRIS Module Power supply |
| Redundant Network Board | Module Redundant Network IRIS/SIMPO |


E. Mattie-Suleiman, Certification Engineer,
On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 16 October 2019
Date of issue: 16 October 2019
Issue number: 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie